

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3240-1288:167 Page 1 of 1

**CATEGORY:** Duct Smoke Detector Housing/Base

**LISTEE:** Gamewell, 12 Clintonville Rd, Northford, CT 06472  
Contact: Brian Reynolds (203) 484-6124 Fax (203) 282-7309

**DESIGN:** Models SS-PD and SS-PDR duct smoke detectors. Units consist of an enclosure, electrical components, sampling and exhaust tubes, and listed photoelectric smoke detector sensor. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 15 to 32 VDC

**INSTALLATION:** In accordance with listee's printed instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical and air velocity rating and UL label.

**APPROVAL:** Listed as duct smoke detectors for use with separately listed compatible fire alarm control units. Suitable for use in ducts where air velocity varies between 100 and 4000 fpm. Refer to listee's Installation Instruction Manual for details.

**XLF:** 3240-0028:205

07-08-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JULY 8, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager